





User Login

Sign into your account

 Username...

 Password...

Login

Tuen Mun Hospital

Overview the LVSB of TMH



H.V. Main Power Supply for H.V. Chiller Units

11kV, 630A VCB with 4 Outgoing Units



Seawater Pump House

1MV, 11kV/380V Transformer for SWP House



H.V. Chiller No.1

1900 TR McQuay Water-cooled Centrifugal Chiller



H.V. Chiller No.2


1900 TR McQuay Water-cooled Centrifugal Chiller



H.V. Chiller No.3

1900 TR McQuay Water-cooled Centrifugal Chiller





Input Power of 630A, H.V. Switchboard for Central Chiller Plant

From CLP Supply 397 kW	H.V. Chiller No.1 122 kW	H.V. Chiller No.2 0 kW	H.V. Chiller No.3 213 kW	Seawater Pump House 62 kW
----------------------------------	------------------------------------	----------------------------------	------------------------------------	-------------------------------------

Summary

Input Power of 1,600A L.V. Switchboard for Seawater Pump (SWP) House

From 1 MV Tx. for SWP 62.0 kW	SWP No.1 16.8 kW	SWP No.2 0 kW	SWP No.3 16.4 kW	SWP No.4 16.9 kW	SWP No.5 0 kW	Chlorination 5.6 kW	Screening 6.3 kW	Others Facilities 16.4 kW
---	----------------------------	-------------------------	----------------------------	----------------------------	-------------------------	-------------------------------	----------------------------	-------------------------------------

Summary

H.V. Chiller No.1 Switchboard

Compressor C1 122 kW	Compressor C2 6.3 kW
--------------------------------	--------------------------------

Summary

H.V. Chiller No.2 Switchboard

Compressor C1 122 kW	Compressor C2 6.3 kW
--------------------------------	--------------------------------

Summary

H.V. Chiller No.3 Switchboard

Compressor C1 122 kW	Compressor C2 6.3 kW
--------------------------------	--------------------------------

Summary

- Power Supply
- Operation Status
- Fault

H.V. Chiller No.1

[View Details](#)

- Power Supply
- Operation Status
- Fault

H.V. Chiller No.2

[View Details](#)

- Power Supply
- Operation Status
- Fault

H.V. Chiller No.3

[View Details](#)

H.V. Chiller No.3

Instantaneous Power : 42 kW
 Current L1 : 23.56 A
 Current L2 : 22.25 A
 Current L3 : 22.79 A
 Earth Leakage Current : 0.12 A

[View Details](#)

- Power Supply
- Operation Status
- Fault

1 MV Transformer for Seawater Pump House

[View Details](#)

Electricity Consumption

Today	32,514 kWh
Yesterday	52,214 kWh
Last Week	113,201 kWh
Last Month	516,658 kWh
Last Year	6,205,698 kWh

[View Details](#)

Electricity Consumption

Today	32,514 kWh
Yesterday	52,214 kWh
Last Week	113,201 kWh
Last Month	516,658 kWh
Last Year	6,205,698 kWh

[View Details](#)

Electricity Consumption

Today	32,514 kWh
Yesterday	52,214 kWh
Last Week	113,201 kWh
Last Month	516,658 kWh
Last Year	6,205,698 kWh


[View Details](#)

Electricity Consumption

Today	32,514 kWh
Yesterday	52,214 kWh
Last Week	113,201 kWh
Last Month	516,658 kWh
Last Year	6,205,698 kWh

[View Details](#)


Input Power of the H.V. Equipment



Instantaneous Chiller Plant Efficiency



Monthly Electricity Consumption of 630A, H.V. Switchboard



Instantaneous Power of H.V. Equipment

Update frequency : every 2 minutes

Summary



From CLP Supply
397 kW



H.V. Chiller No.1
122 kW



H.V. Chiller No.2
0 kW



H.V. Chiller No.3
213 kW



Seawater Pump House
62 kW

Overall Status of H.V. Chiller Units


Update frequency : every 2 minutes



Total Input Power




Total Capacity (%)




Cooling Capacity

Daily Electricity Consumption




Operation Condition of 630A, H.V. Switchboard

Update frequency : every 2 minutes




Voltage



Current




Frequency




Power Factor

Electricity Consumption of 630A, H.V. Switchboard



Electricity Consumption of H.V. Equipment at Last Month



- Power Supply
- Operation Status
- Fault

H.V. Chiller No.1

- Power Supply
- Operation Status
- Fault

H.V. Chiller No.2




- Power Supply
- Operation Status
- Fault

H.V. Chiller No.3


[View Details](#)

- Power Supply
- Operation Status
- Fault

1 MV Transformer for Seawater Pump House




- Power Supply
- Operation Status
- Fault




H.V. Chiller No.1

- Power Supply
- Operation Status
- Fault




H.V. Chiller No.2

- Power Supply
- Operation Status
- Fault






H.V. Chiller No.3

- Power Supply
- Operation Status
- Fault



1 MV Transformer for Seawater Pump House




L.V. Switchboard for LS1/LAG

OPERATION STATUS


Service Area/ Equipment	Status
Main Incomer	Close
Spare	Close
400A 4P MCCB	Fault

INPUT POWER



SWITCHBOARD LAYOUT

630A Incomer
Instantaneous Power : 42 kW



FRONT VIEW - LS1/LAG

LEGEND


- Digital Power Analyser
- Digital Power Meter
- IDMT Off
- IDMT Normal
- IDMT Tripped
- Common Fault
- Current Differential Protection Relay
- Breaker Close
- Breaker Open
- Breaker Tripped
- Heater On
- Heater Off

H.V. Switchboard for H.V. Chiller Plant and Seawater Pump House


OPERATION STSTUS

Service Area/ Equipment	Status
Main Incomer	Close
H.V. Chiller No.1	Close
H.V. Chiller No.2	Fault
H.V. Chiller No.3	Close
1MV Transformer for SWP House	Close
Spare	Open

INPUT POWER




SCHEMATIC WIRING DIAGRAM



Switchboard Status

Legend

- Digital Power Analyzer
- Digital Power Meter
- IDMT Off
- IDMT On
- IDMT Warning
- IDMT Alarm
- Normal Temperature (< 40°C)
- High Temperature (>= 40°C & < 50°C)
- Abnormal Temperature (>= 50°C)
- ON Breaker On
- TRIP Breaker Trip
- OFF Breaker Off



Temp.	Breaker Status	Earth Leakage Current
1. 26.02	1. Off	1. 0.00A
2. 27.18	2. On	2. 6.40A
3. 26.42	3. Off	3. 0.00A
4. 26.75	4. On	4. 0.78A
5. 26.22	5. On	5. 4.40A
6. 26.7	6. On	6. 2.18A
7. 26.24	7. On	7. 0.60A
8. 26.03	8. Off	8. 0.00A
9. 25.23	9. On	9. 0.29A
10. 26.21	10. Off	10. 0.00A
11. 26.55	11. On	11. 7.62A
12. 26.3	12. On	12. 0.00A
13. 26.71	13. On	13. 0.32A
14. 25.47	15. On	15. 1.05A
15. 26.44	16. Off	16. 0.00A
16. 26.41	17. On	17. 0.07A
17. 26.13	18. Off	18. 0.00A
18. 26.39	19. Off	19. 0.00A
19. 26.12	21. Off	21. 0.00A
20. 25.5	22. On	22. 2.02A
21. 25.26	23. Off	23. 0.00A
22. 26.33	24. On	24. 1.93A
23. 26.06	25. On	25. 2.76A
24. 26.56		
25. 25.04		

Department Code

- 00:COMMUNIAL
- 17:HOUSEKEEPING
- 18:PRINTING & DUPLICATING/MAR
- 20:PLANT MAINTENANCE CBS:CENTRAL BATTERY SYSTEM


Busbar

Busbar Status

Legend

- -Normal Temperature (< 40 °C)
- -High Temperature (>= 40 °C & < 50 °C)
- -Abnormal Temperature (>= 50 °C)

Switchboard





Circuit Breaker (CB) Status

Show entries

Search ...

Group	Name	IP	Port	Address	Model	Connection	Value	Time	Setting
LS1/LAG	630A 3P VCB FOR H.V. CHILLER NO.1 – ON/OFF	192.168.1.100	502	1	UMG 96-PA	OK	0	2019-12-11 11:50:40	Alert Setting
LS1/LAG	630A 3P VCB FOR H.V. CHILLER NO.1 – TRIP	192.168.1.100	502	1	UMG 96-PA	OK	0	2019-12-11 12:13:35	Alert Setting
LS1/LAG	630A 3P VCB FOR 1MV TX FOR SWP HOUSE – ON/OFF	192.168.1.100	502	2	UMG 96-PA	OK	0	2019-12-15 16:52:14	Alert Setting
LS1/LAG	630A 3P VCB FOR 1MV TX FOR SWP HOUSE – TRIP	192.168.1.100	502	2	UMG 96-PA	OK	0	2019-12-15 18:11:16	Alert Setting
LS1/LAG	630A 3P VCB FOR H.V. CHILLER NO.3 – ON/OFF	192.168.1.100	502	3	UMG 96-PA	OK	0	2019-12-18 09:12:51	Alert Setting
LS1/LAG	630A 3P VCB FOR H.V. CHILLER NO.3 – TRIP	192.168.1.100	502	3	UMG 96-PA	OK	0	2019-12-18 10:28:34	Alert Setting
LS1/LAG	630A 3P VCB FOR CLP INCOMER – ON/OFF	192.168.1.100	502	4	UMG 509-PRO	OK	0	2019-12-20 15:24:16	Alert Setting
LS1/LAG	630A 3P VCB FOR CLP INCOMER – TRIP	192.168.1.100	502	4	UMG 509-PRO	OK	0	2019-12-20 16:42:17	Alert Setting
LS1/LAG	630A 3P VCB FOR H.V. CHILLER NO.2 – ON/OFF	192.168.1.100	502	5	UMG 96-PA	OK	0	2019-12-25 08:05:21	Alert Setting
LS1/LAG	630A 3P VCB FOR H.V. CHILLER NO.2 – TRIP	192.168.1.100	502	5	UMG 96-PA	OK	0	2019-12-25 09:00:42	Alert Setting

Showing 1 to 10 of 24 entries

Previous 2 3 Next



Device Status

☰ Device

Batch operation

Show entries Search ...

#	Group	Name	IP	Port	Address	Model	Details	State	Field List	Connection	Device ID	T&C	Edit	Setting
<input type="checkbox"/>	LS1/LAG	630A 3P VCB FOR H.V. CHILLER NO.1	192.168.1.100	502	1	UMG 98-PA	Details	Active	Field List	Online	1	T&C	Edit	Alert Setting
<input type="checkbox"/>	LS1/LAG	630A 3P VCB FOR 1MV TX FOR SWP HOUSE	192.168.1.100	502	2	UMG 98-PA	Details	Active	Field List	Online	2	T&C	Edit	Alert Setting
<input type="checkbox"/>	LS1/LAG	630A 3P VCB FOR H.V. CHILLER NO.3	192.168.1.100	502	3	UMG 98-PA	Details	Active	Field List	Online	3	T&C	Edit	Alert Setting
<input type="checkbox"/>	LS1/LAG	630A 3P VCB FOR H.V. CHILLER NO.2	192.168.1.100	502	4	UMG 98-PA	Details	Active	Field List	Online	4	T&C	Edit	Alert Setting
<input type="checkbox"/>	LS1/LAG	630A 3P VCB FOR SPARE	192.168.1.100	502	5	UMG 98-PA	Details	Active	Field List	Online	5	T&C	Edit	Alert Setting
<input type="checkbox"/>	LS1/LAG	630A 3P VCB FOR INCOMER	192.168.1.100	502	6	UMG 509-PRO	Details	Active	Field List	Online	6	T&C	Edit	Alert Setting

Showing 1 to 6 of 6 entries
Previous 2 Next

Overview

Voltage & Current

Power Quality

Phasor Diagram

Harmonic

Trend

Summary

Residual Current Monitoring

Heatmap Analysis

Sankey Diagram

Analyser Display

Energy & Demand

Prediction Chart

Alert Setting

Report


11kV, 630A 3P Incoming VCB

Refresh Time second

Online Value

Active Power	18.60 kW
Apparent Power	20.48 kVA
Power Factor	0.91
Reactive Power	8.32 kVAr
Voltage	L1-L2 : 11430 V L2-L3 : 11345 V L3-L1 : 11264 V
Current	L1: 35.66 A L2: 27.67 A L3: 28.69 A N: 11.06 A Earth Leakage: 3.35 A


Online Active Power




Energy Consumption

Today	342.62 kWh
Yesterday	452.42 kWh
Current Month	9695.97 kWh
Last Month	16382.05 kWh
Current Year	83681.97 kWh
Last Year	0.00 kWh

Online Data



Historical Data



Overview

Voltage & Current

Power Quality

Phasor Diagram

Harmonic

Trend

Summary

Residual Current Monitoring

Heatmap Analysis

Sankey Diagram

Analyser Display

Energy & Demand

Prediction Chart

Alert Setting

Report

11kV, 630A 3P Incoming VCB

Refresh Time second

Voltage (V)

	Online	Average	Maximum	Minimum
L1-L2	11257	10997	11052	10968
L2-L3	11124	10997	11124	10831
L3-L1	11321	11032	11467	10597

Current (A)

	Online	Average	Maximum	Minimum
L1	30.43	32.40	33.56	31.27
L2	29.48	28.76	29.58	28.50
L3	30.42	30.22	30.51	29.21

Online Data



Overview

Voltage & Current

Power Quality

Phasor Diagram

Harmonic

Trend

Summary

Residual Current Monitoring

Heatmap Analysis

Sankey Diagram

Analyser Display

Energy & Demand

Prediction Chart

Alert Setting

Report

11kV, 630A 3P Incoming VCB

Refresh Time second



Power Factor (Cos θ)

	Online	Average	Maximum	Minimum
L1-L2	0.95	0.95	1.00	-1.00
L2-L3	0.94	0.92	1.00	-1.00
L3-L1	0.91	0.91	1.00	-1.00

Total Harmonic Distortion (THD_I) (%)

	Online	Average	Maximum	Minimum
L1-L2	10.06	10.00	624.83	
L2-L3	8.28	8.33	622.75	
L3-L1	7.47	7.68	624.5	

Chart





Overview

Voltage & Current

Power Quality

Phasor Diagram

Harmonic

Trend

Summary

Residual Current Monitoring

Heatmap Analysis

Sankey Diagram

Analyser Display





Energy & Demand

Prediction Chart

Alert Setting

Report

Chart




- Overview
- Voltage & Current
- Power Quality
- Phasor Diagram
- Harmonic
- Trend
- Summary
- Residual Current Monitoring
- Heatmap Analysis
- Sankey Diagram
- Analyser Display
- Energy & Demand
- Prediction Chart
- Alert Setting
- Report

11kV, 630A 3P Incoming VCB

Refresh Time second


Phasor Diagram




Parameter of Phasor Diagram

	Voltage (V)	Current (A)	Angles (Degree)	Power Factor (φ)	Reactive Power (kVAr)
L1-L2	11005	26.5	29.31°	0.87	3.53
L2-L3	11015	28.4	18.29°	0.95	1.94
L3-L1	11045	21.7	22.41°	0.83	2.36
Unbalance	0.5%	1.2%	--	0.89	--

Input Line to Line Voltage (Instantaneous Waveform)




Line Current (Instantaneous Waveform)




- VL1 ● VL2 ● VL3
- IL1 ● IL2 ● IL3

- Overview
- Voltage & Current
- Power Quality
- Phasor Diagram
- Harmonic
- Trend
- Summary
- Residual Current Monitoring
- Heatmap Analysis
- Sankey Diagram
- Analyser Display
- Energy & Demand
- Prediction Chart
- Alert Setting
- Report


Phase Voltage (Instantaneous Waveform)



Line Current (Instantaneous Waveform)



Phase Voltage, Line Current and Active Power (Instantaneous Waveform)



- Overview
- Voltage & Current
- Power Quality
- Phasor Diagram
- Harmonic
- Trend
- Summary
- Residual Current Monitoring
- Heatmap Analysis
- Sankey Diagram
- Analyser Display
- Energy & Demand
- Prediction Chart
- Alert Setting
- Report


11kV, 630A 3P Incoming VCB

Refresh Time second


Online Value

	Voltage (R.M.S.)	Current (R.M.S.)	THD_I (%)	Crest Factor
L1-(L2)	11005	26.5	10.06	1.00
L2-(L3)	11015	28.4	8.28	1.00
L3-(L1)	11045	21.7	7.47	1.00

Fundamental Sinewave plus Harmonics



Individual Harmonic Components



Overview

Voltage & Current

Power Quality

Phasor Diagram

Harmonic

Trend

Summary

Residual Current Monitoring

Heatmap Analysis

Sankey Diagram

Analyser Display

Energy & Demand

Prediction Chart

Alert Setting

Report

11kV, 630A 3P Incoming VCB

Refresh Time second

Online Value


	Voltage (V)	Current (A)	Active Power (kW)	Reactive Power (kVA _r)	Power Factor (ϕ)	Apparent Power (kVA)	Temperature (°C)
L1 (L2)	11005	26.5	431	3.53	0.87	291	27.36
L2 (L3)	11015	28.4	505	1.94	0.95	312	
L3 (L1)	11045	21.7	338	2.36	0.83	240	
Earth Leakage Current	10	0.8	--	--	--	--	
RCM	22	0.3	--	--	--	--	
Unbalance	0.5%	1.2%	--	--	0.89	--	

Chart

Online

Historical

Voltage





L2 (L3)	11015	28.4	505	1.94	0.95	312
L3 (L1)	11045	21.7	338	2.36	0.83	240
Earth Leakage Current	10	0.8	--	--	--	--
RCM	22	0.3	--	--	--	--
Unbalance	0.5%	1.2%	--	--	0.89	--

Overview

Voltage & Current

Power Quality

Phasor Diagram

Harmonic

Trend

Summary

Residual Current Monitoring

Heatmap Analysis

Sankey Diagram

Analyser Display

Energy & Demand

Prediction Chart

Alert Setting


Report

Chart

Online

Historical

Voltage



L2 (L3)	11015	28.4	505	1.94	0.95	312
L3 (L1)	11045	21.7	338	2.36	0.83	240
Earth Leakage Current	10	0.8	--	--	--	--
RCM	22	0.3	--	--	--	--
Unbalance	0.5%	1.2%	--	--	0.89	--

- Overview
- Voltage & Current
- Power Quality
- Phasor Diagram
- Harmonic

Trend

- Summary
- Residual Current Monitoring
- Heatmap Analysis
- Sankey Diagram
- Analyser Display
- Energy & Demand
- Prediction Chart
- Alert Setting
- Report

Chart

Online

Historical



Start Date 24/10/2019

End Date 23/12/2019

Search


« December 2019 »

Su	Mo	Tu	We	Th	Fr	Sa
24	25	26	27	28	29	30
1	2	3	4	5	6	7
8	9	10	11	12	13	14
15	16	17	18	19	20	21
22	23	24	25	26	27	28
29	30	31	1	2	3	4

Voltage

Zoom 1d 7d 1m 6m YTD 1y All

From Oct 2



- Print Chart
- Download PNG Image
- Download JPEG Image
- Download PDF Document
- Download CSV
- Download XLS
- View Data Table
- Open in Highchart Cloud

- Voltage
- Current
- Active Power
- Reactive Power
- Power Factor
- Apparent Power
- Temperature

Overview

Voltage & Current

Power Quality

Phasor Diagram

Harmonic

Trend

Summary

Residual Current Monitoring

Heatmap Analysis

Sankey Diagram

Analysers Display

Energy & Demand

Prediction Chart

Alert Setting

Report

11kV, 630A 3P Incoming VCB

Refresh Time second

General Information

Device	: 11KV, 630A 3P Incomer from CLP Power Supply
Model	: Janitza / UMG 509-PRO
IP Address	: 192.168.1.100
Port	: 502
Connection	: Online

Voltage (V)

Line	Voltage (V)	Phase	Voltage (V)
L1 - L2	11005	L1 - N	--
L2 - L3	11015	L2 - N	--
L3 - L1	11045	L3 - N	--

Current, Power Factor & THD

Line	Current (A)	Power Factor	THD_U (%)	THD_I (%)
L1	26.5	0.87	0.86	5.24
L2	28.4	0.96	1.15	9.52
L3	21.7	0.84	0.80	11.93
N / Total	21.8	0.89	--	--
Earth Leakage Current	6.85	--	--	--
RCM	0.00	--	--	--
Unbalance	1.2%	--	--	--

Power

Phase	Active (kW)	Apparent (kVA)	Reactive (kVAr)
L1	6.57	7.61	3.82
L2	6.56	6.86	1.91
L3	3.61	4.30	2.28
Total	16.74	18.77	8.01
Frequency	49.99 Hz		

Overview

Voltage & Current

Power Quality

Phasor Diagram

Harmonic

Trend

Summary

Residual Current Monitoring

Heatmap Analysis

Sankey Diagram

Analyser Display

Energy & Demand

Prediction Chart

Alert Setting

Report

Current, Power Factor & THD

Line	Current (A)	Power Factor	THD_U (%)	THD_I (%)
L1	26.5	0.87	0.86	5.24
L2	28.4	0.96	1.15	9.52
L3	21.7	0.84	0.80	11.93
N / Total	21.8	0.89	--	--
Earth Leakage Current	6.85	--	--	--
RCM	0.00	--	--	--
Unbalance	1.2%	--	--	--

Power

Phase	Active (kW)	Apparent (kVA)	Reactive (kVAr)
L1	6.57	7.61	3.82
L2	6.56	6.86	1.91
L3	3.61	4.30	2.28
Total	16.74	18.77	8.01
Frequency	49.99 Hz		

Individual Harmonics Current

Order/ Phase	1 (A)	3 (A)	5 (A)	7 (A)	9 (A)	11 (A)	13 (A)	15 (A)	17 (A)	19 (A)	21 (A)	23 (A)	25 (A)	27 (A)	29 (A)	31 (A)	33 (A)	35 (A)	37 (A)	39 (A)	41 (A)	43 (A)	45 (A)	47 (A)	49 (A)	51 (A)	53 (A)	55 (A)	57 (A)	59 (A)	61 (A)	63 (A)
L1	487.47	3.73	14.60	4.13	2.80	1.60	2.06	1.21	1.29	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
L2	488.20	13.74	12.64	6.32	2.74	2.19	1.77	1.34	1.77	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
L3	511.17	5.54	17.57	7.89	2.43	1.16	2.91	1.16	1.46	1.34	0.00	0.00	1.06	0.00	0.00	0.00	1.06	0.00	0.00	0.00	1.06	0.00	0.00	1.06	0.00	0.00	0.00	0.00	0.00	1.06	0.00	0.00

- Overview
- Voltage & Current
- Power Quality
 - Phasor Diagram
 - Harmonic
- Trend
- Summary
- Residual Current Monitoring**
- Heatmap Analysis
- Sankey Diagram
- Analyser Display
- Energy & Demand
- Prediction Chart
- Alert Setting
- Report


11kV, 630A 3P Incoming VCB

Refresh Time second

Live Value



Absolute Value	Actual Value
RCM Channel 1 (L5)	0.00 mA
RCM Channel 2 (L6)	0.00 mA



- Overview
- Voltage & Current
- Power Quality
 - Phasor Diagram
 - Harmonic
- Trend
- Summary
- Residual Current Monitoring
- Heatmap Analysis
- Sankey Diagram
- Analyser Display
- Energy & Demand
- Prediction Chart
- Alert Setting
- Report

11kV, 630A Incoming VCB


« December 2019 »

Su	Mo	Tu	We	Th	Fr	Sa
24	25	26	27	28	29	30
1	2	3	4	5	6	7
8	9	10	11	12	13	14
15	16	17	18	19	20	21
22	23	24	25	26	27	28
29	30	31	1	2	3	4


Heatmap Analysis of Energy Consumption

Start Date

End Date



Total kWh Every 20 Minutes






- Overview
- Voltage & Current
- Power Quality
 - Phasor Diagram
 - Harmonic
- Trend
- Summary
- Residual Current Monitoring
- Heatmap Analysis
- Sankey Diagram**
- Analyser Display
- Energy & Demand
- Prediction Chart
- Alert Setting
- Report

11kV, 630A Incoming VCB

December 2019						
Su	Mo	Tu	We	Th	Fr	Sa
24	25	26	27	28	29	30
1	2	3	4	5	6	7
8	9	10	11	12	13	14
15	16	17	18	19	20	21
22	23	24	25	26	27	28
29	30	31	1	2	3	4

Sankey Diagram of Energy Consumption

Start Date: End Date:



Overview

Voltage & Current

Power Quality

Phasor Diagram

Harmonic

Trend

Summary

Residual Current Monitoring

Heatmap Analysis

Sankey Diagram

Analysers Display


Energy & Demand

Prediction Chart

Alert Setting

Report

11kV, 630A 3P Incoming VCB




Live Device Overview

Display of power analyser “Janitza UMG 509-PRO” for 11kV, 630A 3P Incoming Vacuum Circuit Breaker (VCB) is shown on the left, this image matches the device display at all times. By pressing the six buttons in the bottom of display with the mouse, you are able to tele-control the device directly.

- Overview
- Voltage & Current
- Power Quality
 - Phasor Diagram
 - Harmonic
- Trend
- Summary
- Residual Current Monitoring
- Heatmap Analysis
- Sankey Diagram
- Analyser Display**
- Energy & Demand
- Prediction Chart
- Alert Setting
- Report

11kV, 630A 3P Incoming VCB



Live Device Overview


Display of power analyser “Janitza UMG 509-PRO” for 11kV, 630A 3P Incoming Vacuum Circuit Breaker (VCB) is shown on the left, this image matches the device display at all times. By pressing the six buttons in the bottom of display with the mouse, you are able to tele-control the device directly.

- Overview
- Voltage & Current
- Power Quality
 - Phasor Diagram
 - Harmonic
- Trend
- Summary
- Residual Current Monitoring
- Heatmap Analysis
- Sankey Diagram
- Analyser Display
- Energy & Demand**
- Prediction Chart
- Alert Setting
- Report

11kV, 630A 3P Incoming VCB

Refresh Time second

Instantaneous Power



Energy & Demand

Sliding Window Demand

	kW	kVar	KVA
Consumed	16.83	8.22	18.94

Energy

	kWh	kVarh	kVAh
Consumed	148160.77	36762.14	
Supplied		62.63	
Cons. - Sup	148160.77	36699.51	
Cons. + Sup	148160.77	36824.77	


Sequence

	V	A
Positive	0.22	0.03
Negative	0.00	0.00
Zero	0.00	0.01


- Overview
- Voltage & Current
- Power Quality
 - Phasor Diagram
 - Harmonic
- Trend
- Summary
- Residual Current Monitoring
- Heatmap Analysis
- Sankey Diagram
- Analyser Display
- Energy & Demand
- Prediction Chart**
- Alert Setting
- Report

11kV, 630A 3P Incoming VCB

Daily Energy Consumption Prediction



Monthly Energy Consumed Prediction





- Overview
- Voltage & Current
- Power Quality
 - Phasor Diagram
 - Harmonic
- Trend
- Summary
- Residual Current Monitoring
- Heatmap Analysis
- Sankey Diagram
- Analyser Display
- Energy & Demand
- Prediction Chart
- Alert Setting
- Report

11kV, 630A 3P Incoming VCB

Setting Details

Alert Group

Line	Under Voltage	Over Voltage	Over Current	Lower Power Factor	Enable
L1-(L2)	<input type="text"/> V	<input type="text"/> V	<input type="text"/> A	<input type="text"/>	<input checked="" type="checkbox"/>
L2-(L3)	<input type="text"/> V	<input type="text"/> V	<input type="text"/> A	<input type="text"/>	<input type="checkbox"/>
L3-(L1)	<input type="text"/> V	<input type="text"/> V	<input type="text"/> A	<input type="text"/>	<input type="checkbox"/>

Unbalance

%

Current Unbalance in three-phase 4-wire installation is given by :

$$I_u = (I_d \times 100) / I_a$$

where I_u = percentage current unbalance

I_d = maximum current deviation from the average current

I_a = average current among three phases

Maximum current unbalance (unbalanced single-phase loads distribution) should not exceed 10% in compliance with BEC 2018.

Save



General Report

Power Consumption Report >

Voltage Report

Current Report

Graph Report

Auto Generated Report

General Report

*From Date

2019-12-01

*To Date

2019-12-20

23 59

*Field Selection All

- Voltage L1-L2 (V)
- Voltage L2-L3 (V)
- Voltage L3-L1 (V)
- Voltage L1-N (V)
- Voltage L2-N (V)
- Voltage L3-N (V)
- Current L1 (A)
- Current L2 (A)
- Current L3 (A)
- Current N (A)
- Active Power L1 (kW)

Record Period

All Record

Report Format

CSV

Generate

By Device By Tag By Customer

Selectable Items

Search ...

- 11kV H.V. CHILLER PLANT
- 400A INCOMING ACB
- 400A H.V. CHILLER NO.1
- 400A H.V. CHILLER NO.3
- 100A 1MV TRANSFORMER FOR SWP
- 400A H.V. SPARE



Selected Items

Search ...

- 11kV H.V. CHILLER PLANT
- 400A H.V. CHILLER NO.2





- General Report
- Power Consumption Report**
 - Short by Day
 - Short by Time
- Voltage Report
- Current Report
- Graph Report

Auto Generated Report

Power Consumption Report (Short by Day)

*From Date:

*To Date:

Period:

« December 2019 »						
Su	Mo	Tu	We	Th	Fr	Sa
24	25	26	27	28	29	30
1	2	3	4	5	6	7
8	9	10	11	12	13	14
15	16	17	18	19	20	21
22	23	24	25	26	27	28
29	30	31	1	2	3	4

By Device | **By Tag** | By Customer

Selectable Items

Search ...

- Meter Devices
- 400A INCOMING ACB
- 400A H.V. CHILLER NO.1
- 400A H.V. CHILLER NO.2
- 400A H.V. CHILLER NO.3
- 100A 1MV TRANSFORMER FOR SWP
- 400A H.V. SPARE

Selected Items

Search ...



- General Report
- Power Consumption Report ▾
- Short by Day
- Short by Time
- Voltage Report
- Current Report
- Graph Report
- Auto Generated Report

Power Consumption Report (Short by Time)

*From Date: 2019-12-23

*To Date: 2019-12-23

23 59

Whole Period

General

By Device By Tag By Customer

Add Remove

--

- General Report
- Power Consumption Report
- Short by Day
- Short by Time
- Voltage Report
- Current Report
- Graph Report
- Auto Generated Report

Power Consumption Report (Short by Time)

*From Date
2019-12-17
0 0

*To Date
2019-12-23
23 59

Whole Period

Generate

Select Device List

Name

Please input name

- 11kV H.V. CHILLER PLANT
- 400A INCOMING ACB
- 400A H.V. CHILLER NO.1
- 400A H.V. CHILLER NO.2
- 400A H.V. CHILLER NO.3
- 100A 1MV TRANSFORMER FOR SWP
- 400A H.V. SPARE

Save Close



- General Report
- Power Consumption Report >
- Voltage Report**
- Current Report
- Graph Report

Auto Generated Report

Voltage Report

*From Date: 2019-12-23

*To Date: 2019-12-23

*Range (%): 6

Generate

- By Device
- By Tag
- By Customer

Selectable Items

Search ...

- 11kV H.V. CHILLER PLANT
- 400A INCOMING ACB
- 400A H.V. CHILLER NO.1
- 400A H.V. CHILLER NO.2
- 400A H.V. CHILLER NO.3
- 100A 1MV TRANSFORMER FOR SWP
- 400A H.V. SPARE

Navigation buttons: >>, >, <, <<

Selected Items

Search ...

- (Empty list)



- General Report
- Power Consumption Report >
- Voltage Report
- Current Report**
- Graph Report

Auto Generated Report

Current Report

*From Date: 2019-12-23

*To Date: 2019-12-23

Generate

By Device | By Tag | By Customer

Selectable Items

Search ...

- 11kV H.V. CHILLER PLANT
- 400A INCOMING ACB
- 400A H.V. CHILLER NO.1
- 400A H.V. CHILLER NO.2
- 400A H.V. CHILLER NO.3
- 100A 1MV TRANSFORMER FOR SWP
- 400A H.V. SPARE

Navigation buttons: >>, >, <, <<

Selected Items

Search ...

- (Empty list)




- General Report
- Power Consumption Report >
- Voltage Report
- Current Report
- Graph Report

Auto Generated Report

11kV, 630A 3P Incoming VCB

- Online
- Historical
- Voltage
 - Voltage L1-N
 - Voltage L2-N
 - Voltage L3-N
 - Voltage L1-L2
 - Voltage L2-L3
 - Voltage L3-L1
- Current
- Frequency
- Active Power
- Reactive Power
- Apparent Power
- Cos θ
- THD



Voltage	Actual Value	Min Value	Max Value	Options
Voltage L1 - N	229.69 V	226.53 V	234.51 V	▶
Voltage L2 - N	229.27 V	225.64 V	233.79 V	▶
Voltage L3 - N	231.38 V	228.11 V	234.04 V	▶

Clear Graph

Print Graph

11kV, 630A 3P Incoming VCB

General Report

Power Consumption Report >

Voltage Report

Current Report

Graph Report

Auto Generated Report

Online Historical

Start

19/11/2019

Stop

Prev Next

Nov 2019

Su Mo Tu We Th Fr Sa

3 4 5 6 7 8 9

10 11 12 13 14 15 16

17 18 19 20 21 22 23

24 25 26 27 28 29 30

Voltage L3-N

Voltage L1-L2

Voltage L2-L3

Voltage L3-L1

Current

Frequency


Active Power

Reactive Power

Apparent Power

Cos θ

THD



Voltage	Actual Value	Min Value	Max Value	Options
Voltage L1 - N	229.69 V	226.53 V	234.51 V	▶
Voltage L2 - N	229.27 V	225.64 V	233.79 V	▶
Voltage L3 - N	231.38 V	228.11 V	234.04 V	▶

Clear Graph

Print Graph



General Report

Power Consumption Report >

Voltage Report

Current Report

Graph Report

Auto Generated Report

Auto Generated Report

Show 10 entries

Search ...

Report Date	File Name
2019-12-09	general_report(20191209-20101215).xlsx
2019-12-09	voltage_report(20191209-20101215).zip
2019-12-09	current_report(20191209-20101215).zip
2019-12-09	power_consumption_report(20191209-20101215).xlsx
2019-12-02	general_report(20191202-20101208).xlsx
2019-12-02	voltage_report(20191202-20101208).zip
2019-12-02	current_report(20191202-20101208).zip
2019-12-02	power_consumption_report(20191202-20101208).xlsx
2019-11-25	general_report(20191125-20101201).xlsx
2019-11-25	voltage_report(20191125-20101201).zip

Showing 1 to 10 of 95 entries

Previous 1 2 3 4 5 ... 10 Next




Event

Events

List of events

Under voltage - L1	1
2020/3/18 下午3:36:04,632 0.01s	
Over voltage - L1	2
2020/3/18 下午3:34:12,255 9.20s	
Over voltage - L1	3
2020/3/18 下午3:33:50,852 0.02s	
Over voltage - L2	4
2020/3/18 下午3:33:50,848 0.01s	
Over voltage - L2	5
2020/3/18 下午3:33:29,447 0.04s	
Over voltage - L3	6
2020/3/18 下午3:33:29,444 0.01s	
Under voltage - L2	7
2020/3/18 下午3:33:24,092 1.76s	
Over voltage - L2	8
2020/3/18 下午3:31:58,472 3.30s	
Over voltage - L3	9
2020/3/4 下午10:10:38,476 1.21s	
Under voltage - L3	10
2020/3/4 下午10:06:10,910 43.18s	
Under voltage - L1	11
2020/3/4 下午10:06:10,907 12.35s	
Under voltage - L2	12



- Voltage L1-N
- Voltage L2-N
- Voltage L3-N
- Voltage L4-N
- Voltage L1-L2
- Voltage L2-L3
- Voltage L3-L1
- Current L1
- Current L2
- Current L3
- Current L4

Duration	Limit	Maximum value	Minimum value	Average value	Reason
43.18s	207 V	184.5 V	184.5 V	184.5 V	Under voltage
Starttime		2020/3/4 下午10:06:10,910			



Alarm

Current Alarm

Download Report

Minimize

Show

Group ▾	Location ▾	Name ▾	IP ▾	Port ▾	Address ▾	Model ▾	Created Time ▾	Updated Time ▾	Description ▾	Muted By ▾	Muted Time ▾	Action ▾
LS1/LAG		630A 3P VCB FOR H.V. CHILLER NO.1 – ON/OFF	192.168.1.100	502	1	UMG 98-PA	2019-10-08 15:05:37	2019-10-12 13:16:37	Off			Mute
LS1/LAG		630A 3P VCB FOR 1MV TX FOR SWP HOUSE – ON/OFF	192.168.1.100	502	3	UMG 98-PA	2019-12-14 10:53:45	2019-12-25 18:27:27	Off	Admin	2019-12-16 10:35:42	
LS1/LAG		630A 3P VCB FOR H.V. CHILLER NO.3 – ON/OFF	192.168.1.100	502	8	UMG 98-PA	2019-10-13 10:53:45	2019-10-16 11:37:54	Off			Mute
LS1/LAG		630A 3P VCB FOR H.V. CHILLER NO.1 – ON/OFF	192.168.1.100	502	10	UMG 98-PA	2019-11-20 10:53:45	2019-11-30 17:42:31	Off			Mute
LS1/LAG		630A 3P VCB FOR SPARE – ON/OFF	192.168.1.100	502	16	UMG 98-PA	2019-11-05 10:53:45	2019-12-12 08:26:43	Off			Mute

Showing 1 to 5 of 9 entries

Previous 2 Next

Resume Normal

Download Report

Minimize

Show entries

Group ▾	Location ▾	Name ▾	IP ▾	Port ▾	Address ▾	Model ▾	Created Time ▾	Updated Time ▾	Description ▾	Action
LS1/LAG		630A 3P VCB FOR H.V. CHILLER NO.1 – IDMT	192.168.1.100	502	1	UMG 98-PA	2019-10-08 15:05:37	2019-10-12 13:16:37	Communication Error	Acknowledge All
LS1/LAG		630A 3P VCB FOR 1MV TX FOR SWP HOUSE – IDMT	192.168.1.100	502	3	UMG 98-PA	2019-12-14 10:53:45	2019-12-25 18:27:27	Communication Error	Acknowledge
LS1/LAG		630A 3P VCB FOR H.V. CHILLER NO.3 – IDMT	192.168.1.100	502	8	UMG 98-PA	2019-10-13 10:53:45	2019-10-16 11:37:54	Communication Error	Acknowledge
LS1/LAG		630A 3P VCB FOR H.V. CHILLER NO.1 – IDMT	192.168.1.100	502	10	UMG 98-PA	2019-11-20 10:53:45	2019-11-30 17:42:31	Communication Error	Acknowledge
LS1/LAG		630A 3P VCB FOR SPARE – IDMT	192.168.1.100	502	16	UMG 98-PA	2019-11-05 10:53:45	2019-12-12 08:26:43	Communication Error	Acknowledge



Alarm Testing

Trigger Alarm

Alarm Type

Over Current

Device

630A 3P INCOMING VCB

Mobile Number

91234567

Submit

- Alarm Testing
- Setting
- User Management
- User Group Management
- Admin Utils
- Logout
- Logout and untrust device

Select	Alarm	Sampling	Resolution	Threshold	Alert Method
<input checked="" type="checkbox"/>	Transient Voltage	within 50 us from point to point	400 samples/cycle	L1 Rated Voltage - 4%	PQMS
<input type="checkbox"/>	Transient Voltage	within 50 us from point to point	400 samples/cycle	L2 Rated Voltage - 4%	PQMS
<input type="checkbox"/>	Transient Voltage	within 50 us from point to point	400 samples/cycle	L3 Rated Voltage - 4%	PQMS
<input type="checkbox"/>	Transient Voltage	within 50 us from point to point	400 samples/cycle	N-E Rated Voltage - 4%	PQMS
<input type="checkbox"/>	Under Voltage	1 cycle of R.M.S	400 samples/cycle	L1 Rated Voltage - 4%	PQMS, SMS
<input type="checkbox"/>	Under Voltage	1 cycle of R.M.S	400 samples/cycle	L2 Rated Voltage - 4%	PQMS, SMS
<input type="checkbox"/>	Under Voltage	1 cycle of R.M.S	400 samples/cycle	L3 Rated Voltage - 4%	PQMS, SMS
<input type="checkbox"/>	Under Voltage	1 cycle of R.M.S	400 samples/cycle	N-E Rated Voltage - 4%	PQMS, SMS
<input type="checkbox"/>	Over Current	1 cycle of R.M.S	400 samples/cycle	L1 >Rated Current	PQMS, SMS
<input type="checkbox"/>	Over Current	1 cycle of R.M.S	400 samples/cycle	L2 >Rated Current	PQMS, SMS
<input type="checkbox"/>	Over Current	1 cycle of R.M.S	400 samples/cycle	L3 >Rated Current	PQMS, SMS



Setting

- Alarm Testing
- Setting
- User Management
- User Group Management
- Admin Utils
- Logout
- Logout and untrust device

Name	Setting
SMTP Setting	Edit



Setting – Edit SMTP

Setting Details

SMTP Server

Port

SSL Mode

Authorizer

Username

Password

Save

Cancel



User Management

- Alarm Testing
- Setting
- User Management
- User Group Management
- Admin Utils
- Logout
- Logout and untrust device

New

#	Name	Email	Mobile	Login Name	Alert Group	Status	Setting
1	Tai Man, Chan	chantaiman@email.com	91234567	TMChan	11kV H.V. Chiller Plant	Active	Edit
2	Sui Man, Chan	chansuiman@email.com	92345678	SMChan	11kV H.V. Chiller Plant	Active	Edit
3	Chung Man, Chan	chanchungman@email.com	93456789	CMChan	11kV H.V. Chiller Plant	Active	Edit
4	Peter, Chan	peterchan@email.com	94567890	PeterChan	11kV H.V. Chiller Plant	Active	Edit
5	Mary, Chu	marychu@email.com	95678901	MaryChu	11kV H.V. Chiller Plant	Active	Edit
6	Tom, Lee	tomlee@email.com	96789012	TomLee	Seawater Pump Room	Active	Edit
7	Paul, Cheung	paulcheung@email.com	97890123	PaulCheung	Seawater Pump Room	Active	Edit

Total : 7 Record # 10

First Previous 1 Next Last



User Management - Add

User Details

Name

Contact Name

E-mail

Email

Mobile No.

Mobile

User Name

Username

Password

Password

Confirm Password

Confirm Password

User Group(s)

- Admin
- Manager
- Engineer
- Operation
- Viewer
- Guest

Status

Active

Alert Group(s)

- 11kV H.V. Chiller Plant
- Seawater Pump Room

Save

Cancel



User Group Management

- Alarm Testing
- Setting
- User Management
- User Group Management**
- Admin Utils
- Logout
- Logout and untrust device

New

#	Group Name	Status	Setting
1	Admin	Active	Edit
2	Manager	Active	Edit
3	Engineer	Active	Edit
4	Operator	Active	Edit
5	Viewer	Active	Edit
6	Guest	Active	Edit

Total : 6 Record # 10

First Previous 1 Next Last

User Group Management - Add

User Group Details

User Group Name

Group Name

Access Rights

Selectable Items

Search ...

Device

- Device - Batch Status
- Device - Field
- Device - Setting

Checking

- Checking - List

Compare

- Compare - Compare Detail
- Compare - List

Device Group

- Device Group - Edit
- Device Group - List

Diagram

- Diagram - List

Image

- Image - Edit
- Image - List

Setting

- Setting - Edit
- Setting - Email Setting



Selected Items

Search ...

Alarm

- Alarm - Acknowledged List
- Alarm - Batch Status
- Alarm - Batch Status - Acknowledge All
- Alarm - Current Active List
- Alarm - List
- Alarm - Resume Normal List

Alert

- Alert - List

Alert BMS

- Alert BMS - List

Alert Group

- Alert Group - List

Chart

- Chart - Chart page
- Chart - Details
- Chart - List

Chart Device

- Chart Device - Chart
- Chart Device - Chart Details

Status

Active

Save

Cancel



Device Management

Diagram Management

Project Management

Device Management

Device List Export

Export

*Import Mode :

Overwrite

*File :

No file chosen

Browse

File size limit : 20M

Import

Alarm Testing

Setting

User Management

User Group Management

Admin Utils

Logout

Logout and untrust device



Device Management

Diagram Management

Project Management

Diagram Management

Diagram Export

Export

- Alarm Testing
- Setting
- User Management
- User Group Management
- Admin Utils
- Logout
- Logout and untrust device

Diagram Import

*Import Mode :

Overwrite

*File :

No file chosen

Browse

File size limit : 20M

Import



- Device Management
- Diagram Management
- Project Management**

Project Management

- Alarm Testing
- Setting
- User Management
- User Group Management
- Admin Utils**
- Logout
- Logout and untrust device

Project Setting

*Project Name

Logo

Login Layout

Frontpage

Frontpage Template

Index / index_zoom / index_bms

Show Alarm Popup?
 ▾

Show Alarm Count At Left Top?
 ▾

Play Alarm Sound?
 ▾

Footer

Seawater Pump No.1

- Power Supply
- Operation Status
- Fault

Seawater Pump No.2

- Power Supply
- Operation Status
- Fault

Seawater Pump No.3

- Power Supply
- Operation Status
- Fault

Seawater Pump No.4


- Power Supply
- Operation Status
- Fault

Seawater Pump No.5

- Power Supply
- Operation Status
- Fault

Electro-chlorination System

- Power Supply
- Operation Status
- Fault



Seawater Pump No.1

Instantaneous Power : 42 kW
 Current L1 : 23.56 A
 Current L2 : 22.25 A
 Current L3 : 22.79 A
 Earth Leakage Current : 0.12 A


[View Details](#)

63A DB for Lighting System

Instantaneous Power : 2.3 kW
 Current L1 : 13.56 A
 Current L2 : 12.25 A
 Current L3 : 12.79 A
 Earth Leakage Current : 0.12 A

[View Details](#)


Lighting System



Energy Consumption

Today	32,514 kWh
Yesterday	52,214 kWh
Last Week	113,201 kWh
Last Month	516,658 kWh
Last Year	6,205,698 kWh


Socket Outlet



Energy Consumption

Today	32,514 kWh
Yesterday	52,214 kWh
Last Week	113,201 kWh
Last Month	516,658 kWh
Last Year	6,205,698 kWh


Screening System



Energy Consumption

Today	32,514 kWh
Yesterday	52,214 kWh
Last Week	113,201 kWh
Last Month	516,658 kWh
Last Year	6,205,698 kWh

General Power



Energy Consumption

Today	32,514 kWh
Yesterday	52,214 kWh
Last Week	113,201 kWh
Last Month	516,658 kWh
Last Year	6,205,698 kWh

Air Conditioners



Energy Consumption

Today	32,514 kWh
Yesterday	52,214 kWh
Last Week	113,201 kWh
Last Month	516,658 kWh
Last Year	6,205,698 kWh


Active Harmonic Filter




Energy Consumption

Today	32,514 kWh
Yesterday	52,214 kWh
Last Week	113,201 kWh
Last Month	516,658 kWh
Last Year	6,205,698 kWh

Input Power of the Equipment at Seawater Pump (SWP) House




Monthly Electricity Consumption of 1,600A L.V. Switchboard




Instantaneous Power of all Equipment at Seawater Pump (SWP) House

Update frequency : every 2 minutes

Summary




Daily Electricity Consumption




Operation Condition of 1,600A, L.V. Switchboard for SWP House


Update frequency : every 2 minutes



Electricity Consumption of 1,600A, L.V. Switchboard for SWP House



Electricity Consumption of SWP House at Last Month



Power Supply

SWP No.1

Power Supply

SWP No.2

Power Supply

SWP No.3

Power Supply

SWP No.4

Power Supply

SWP No.5

Power Supply

Chlorination

Power Supply

DB-SCS (200A)

Screening System

Power Supply

DB-LGT (63A)

Lighting System

Power Supply

DB-SO (63A)

Socket Outlet

Power Supply

DB-GP (150A)

General Power

Power Supply

DB-AC (200A)

Air Conditioners

Power Supply

Harmonic Filter

Operation Condition of Seawater Pump No.1

Update frequency : every 2 minutes



Operation Status	Running
Start Times	203
Running Hours	7873.4
Reset Running Hours	

Input Power

Voltage, L1-L2

Frequency

Power Factor



Power Supply

SWP No.1

Power Supply

SWP No.2

Power Supply

SWP No.3

Power Supply

SWP No.4

Power Supply

SWP No.5

Power Supply

Chlorination

Power Supply

DB-SCS (200A)

Screening System

Power Supply

DB-LGT (63A)

Lighting System

Power Supply

DB-SO (63A)

Socket Outlet

Power Supply

DB-GP (150A)

General Power

Power Supply

DB-AC (200A)

Air Conditioners

Power Supply

Harmonic Filter

Operation Condition of Lighting System for SWP House

Update frequency : every 2 minutes



Input Power



Voltage, L1-N



Voltage, L2-N



Voltage, L3-N




Frequency




Power Factor

Current of Lighting System for SWP House



Electricity Consumption of Lighting System for SWP House



Monthly

Daily

Monthly

Quarterly

Yearly

Overview

Detailed View

Power Supply

SWP No.1

Power Supply

SWP No.2

Power Supply

SWP No.3

Power Supply

SWP No.4

Power Supply

SWP No.5

Power Supply

Chlorination

Power Supply

DB-SCS (200A)

Screening System

Power Supply

DB-LGT (63A)

Lighting System

Power Supply

DB-SO (63A)

Socket Outlet

Power Supply

DB-GP (150A)

General Power


Power Supply

DB-AC (200A)

Air Conditioners

Power Supply

Harmonic Filter




Efficiency of the Harmonic Filter of L.V. Switchboard for SWP House


Update frequency : every 2 minutes



THD_U



THD_I




Frequency




Power Factor

Harmonic Voltage of the L.V. Switchboard for SWP house



Harmonic Current of the L.V. Switchboard for SWP House



Overview

Voltage & Current

Power Quality

Phasor Diagram

Harmonic

Trend

Summary

Residual Current Monitoring

Heatmap Analysis

Sankey Diagram

Analyser Display

Energy & Demand

Prediction Chart

Alert Setting

Report


380V, 1600A 3P Incoming ACB

Refresh Time second

Online Value

Active Power	18.60 kW
Apparent Power	20.48 kVA
Power Factor	0.91
Reactive Power	8.32 kVAr
Voltage	L1-L2 : 380 V L2-L3 : 382 V L3-L1 : 381 V
Current	L1: 35.66 A L2: 27.67 A L3: 28.69 A N: 11.06 A Earth Leakage: 3.35 A


Online Active Power




Energy Consumption

Today	342.62 kWh
Yesterday	452.42 kWh
Current Month	9695.97 kWh
Last Month	16382.05 kWh
Current Year	83681.97 kWh
Last Year	0.00 kWh


Online Data



Historical Data



- Power Supply
- Operation Status
- Fault




Total Capacity


H.V. Chiller No.2

Compressor C1

Operation Status	Standby
Start Times	203
Machine Running Hours	7873.4




Input Power
0 kW




Cooling Capacity
0 kW

Running Current




Compressor C2

Operation Status	Fault
Start Times	234
Machine Running Hours	9856.7




Input Power
0 kW



Cooling Capacity
0 kW

Running Current



Power Supply Condition for H.V. Chiller No.2



Total Input Power



Voltage, L1-L2




Frequency




Power Factor


Monthly Instantaneous Active Power



Electricity Consumption



- Power Supply
- Operation Status
- Fault



Total Capacity

H.V. Chiller No.3

Compressor C1

Operation Status

Running



Start Times

203


Machine Running Hours

7873.4

Input Power
603.7 kW

Cooling Capacity
2535.6 kW

Running Current



Compressor C2

Operation Status

Standby



Start Times

234


Machine Running Hours

9856.7

Input Power
0 kW

Cooling Capacity
0 kW

Running Current



Power Supply Condition for H.V. Chiller No.3



Total Input Power



Voltage, L1-L2




Frequency




Power Factor

Monthly Instantaneous Active Power



Electricity Consumption



Special News Latest

To cope with the Government's plan to gradually resume public services in an orderly manner, the Resource Centre of the Hong Kong Observatory (HKO) located at 23/F, Mira Place Tower A, Tsim Sha Tsui will provide service from 10 am to 4 pm from Monday to Friday commencing 2 March. The HKO will continue maintaining essential shift arrangements to provide round-the-clock monitoring, forecasting and warning services. Public talks and public visits to the HKO, including HKO guided tours on weekends, will still be suspended temporarily.

Updated at 07:20 on 29 Feb,2020

Current Weather Update at 17:40

HKO
↓ 20°C ↑ 23°C ?

21.0°C
87%

King's Park
UV Index 0.1 (Low)


Innovate with Science,
Serve with Heart

Current Weather

Regional Weather

Regional Weather

Temperature



Air temperature (°C) at 17:40 on 20 Mar

Details

Automatic Regional Weather Forecast

Highlights

New

Interactive Map of Storm Damage by Mangkhut

My Little Observatory

The Friends of the Observatory